



Jockey Pump Maintenance Checklist

10 planned preventive maintenance tasks · Free PDF from PM Assist

A practical starting point for planned preventive maintenance. Always refer to the manufacturer's O&M manual and site-specific requirements.

Visual Checks

- ☐ Inspect for leaks at the pump, seals, and connections
- ☐ Check for system leaks causing frequent jockey operation

Functional Checks

- ☐ Confirm the jockey pump starts and stops at its set pressures
- ☐ Verify cut-in/cut-out settings are correct relative to the main fire pumps
- ☐ Check the pump maintains system pressure without excessive cycling
- ☐ Check the pressure switch/transducer and any small pressure vessel
- ☐ Confirm motor operation and current
- ☐ Inspect isolation valves and non-return valve operation
- ☐ Verify the control panel status and any fault indication

Record Keeping

- ☐ Record pressures, cut-in/out settings, and operation in the log

Maintenance Frequency

Weekly

- Confirm jockey maintains pressure
- Check cut-in/out operation
- Note any excessive cycling

Annually

- Verify pressure settings vs main pumps
- Seal and connection inspection
- Pressure switch/vessel check
- Control panel and electrical check