



Petrol & Oil Interceptor Maintenance Checklist

7 planned preventive maintenance tasks · Free PDF from PM Assist

A practical starting point for planned preventive maintenance. Always refer to the manufacturer's O&M manual and site-specific requirements.

Visual Checks

- ☐ Inspect oil and silt levels in each chamber
- ☐ Inspect covers are secure and the chamber is structurally sound

Functional Checks

- ☐ Test the high-level oil alarm

Cleaning & Housekeeping

- ☐ Arrange emptying before oil or silt reach the design limit
- ☐ Check inlet and outlet pipes and any coalescer are clear

Safety Checks

- ☐ Confirm spill kits are stocked near fuel and loading areas

Record Keeping

- ☐ Keep waste consignment notes for oil and silt removed

Maintenance Frequency

Monthly

- Check the alarm panel
- Visual check of covers

Every 6 Months

- Inspection and emptying
- Alarm test
- Silt removal